



Applications:

ICU

NICU

PACU

Transitional

Step-Down

Patient Rooms

LDR Post-Partum

Key Features

- Easily configurable, scalable and adaptable height and width
- Ergonomic placement of services to minimize caregiver bending and reaching
- Integrated Equipment Management Rail System to facilitate change and optimizes bedside workflow
- May be recessed with only 3rd depth in the wall and less than 1st reveal on the surface. May be surface mounted as well.
- May incorporate back-lit artwork and high-style finishes.



Construction Specification

The surface mounted Headwall Unit shall be constructed of .094" thick 6063-t 5 alloy and extruded aluminum for the structural frame. All exposed aluminum surface, including rails, shall be clear anodized. Each vertical edge can be equipped with Paladin Healthcare's 45° two track system as an integral part of the main frame (other options available). Integrated rails are designed to manage hospital equipment and accessories both horizontally and vertically. An all aluminium fascia strip can be used to house medical gas outlets and electrical devices. All gas and electrical terminations are located above the ceiling. The decorative laminated panels shall be constructed of high-density fire-retardant particle board. These panels are easily removable for maintenance or addition of in-wall services. All mounting accessories can be provided as needed. The color finishes are at the customer's choice. This product is cULus listed.

Fascia

Access panels are constructed of high-pressure laminate over a high-density fire-retardant particle board. An all-aluminum fascia strip can be installed to house medical gas outlets and electrical devices.

Medical Gas

Console style medical gas outlets shall be supplied, installed, and manifolded by Paladin Healthcare. Connection points for copper tubing are located 6" above top of unit. Medical gas outlets will be manifolded with type L copper piping. All piping will be brazed as indicated on the shop drawings. Installation and testing shall comply with National Fire Protection Association NFPA99 et CSA Z7396.1

Electrical Equipment

Electrical devices shall be supplied and pre-wired by Paladin Healthcare. Wiring shall run through metal raceway and terminate at the top of the unit connected to the Hospital electrical system. Conductors shall be #12 AWG stranded copper wire for normal and emergency power circuits. All devices shall be grounded with #10 AWG green jacket stranded copper wire. All electrical receptacles are NEMA 5-15/20R, 125 volts AC, hospital grade and comply with CSA and are cULus listed. Receptacles shall be red for emergency and ivory for normal power.

Communication

Communication devices shall be supplied and installed by others. Provisions for devices shall be coordinated with Paladin Healthcare. Metal raceway with pull cord extending from service provision to junction box will be supplied.

Integrated rails (Optional)

Horizontal and vertical rails are to be clear anodized. The numbers of rails required will be identified on the final shop drawings.

Lighting (Optional)

Overbed lighting can be provided by Paladin Healthcare. Fixtures are available in 3' and 4' and can include direct, indirect, and night light.

Accessories (Optional)

Paladin Healthcare can provide the required accessories needed as per shop drawing. Please see Paladin Healthcare's accessory catalogue for more information.

Drawings and submittals


Project specific drawings will be produced for every order. Paladin Healthcare will manufacture equipment as per signed drawings.

Site Installation


Installation of the product includes but is not limited to receiving, storage, erection, clean-up, and waste disposal. All units shall be installed in accordance with Paladin Healthcare's installation instructions. The mechanical and electrical contractor shall provide the final connection to the hospital system. The contractor has the responsibility to ensure that every unit complies with all National, State and Local Codes. The contractor shall supply all necessary installation material.

Warranty

Paladin Healthcare warrants its architectural products to be free from defects in material and workmanship for a period of twelve (12) months from the date of install. Within this period, Paladin Healthcare will repair or replace any part on site, or at the factory, which is proven to be defective at Paladin Healthcare's cost. Furthermore, Paladin Healthcare will warrant its material to be free from defect for an additional period of four (4) years [five (5) years from date of install]. Within this period, Paladin Healthcare will replace any part, at no charge, which is proven to be defective. Shipping and Installation costs after the first twelve (12) months will be borne by the customer.



** Unit shown: Legacy Series 22" Headwall*



* Unit shown: Legacy Series 22" Headwall



Ordering Information:

Item

Legacy Series
Surface Mounted Vertical Headwall